

CITY OF NORTHGLENN

**2020 Concrete Trail Program
IFB 2020-006**

**ADDENDUM NO. 1
DATED: May 22, 2020**

TO: PROSPECTIVE BIDDERS

The following adds to, supplements, amends, or clarifies by way of explanation, portions of the Contract Documents for the above-named project.

It will be the responsibility of the Bidders to acknowledge receipt of Addenda as part of their submitted bids. Failure to do so will be grounds for the City to consider the bid non-responsive.

The Contract Documents are hereby modified by the following items:

SPECIFICATIONS:

DRAWINGS: NONE

QUESTIONS AND ANSWERS:

Q1. Is a bid bond required for this project?

A1. No, a bid bond is not required for this project.

Q2: Does Concrete Combination SW/C&G and Concrete Sideway (Greenway Trails) require a different concrete mix design

A2. No, both items use the same mix design. Please reference CDOT Concrete Class B (4500 PSI) for material specification.

City of Northglenn
Kyle Haworth
Civil Engineer I

Attachments: Pre-Bid Conference Sign-In Sheet

END OF ADDENDUM NO. 1



**2020 Concrete Trails Program – IFB 2020-006
Pre-Bid Meeting Sign-In Sheet**

**Tuesday, May 12, 2020, 11:00 AM
12301 Claude Court, Northglenn, CO 80233**

	Company	Representative Name	Phone Number	Email Address
1	Keene Concrete	Darren Diederich		Darren@Keeneconcrete.com
2	Noraa Concrete Construction	Lisa Wagner	303-637-9233	lisa@noraaconcrete.com
3	Lisa McDevitt	Western States Reclamation	720-701-0702	lmcdevitt@wsreclamation.com
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				