

CITY OF NORTHGLENN

**112th Ave Corridor Improvements
IFB 2018-018**

ADDENDUM NO. 2

DATED: November 5, 2018

TO: PROSPECTIVE BIDDERS

The following adds to, supplements, amends, or clarifies by way of explanation, portions of the Contract Documents for the above-named project.

It will be the responsibility of the Bidders to acknowledge receipt of Addenda as part of their submitted bids. Failure to do so will be grounds for the City to consider the bid non-responsive.

The Contract Documents are hereby modified by the following items:

SPECIFICATIONS: None

DRAWINGS: None

QUESTIONS AND ANSWERS:

1. You are calling out for thermoplastic as long line. This is not typically done in thermo, but as epoxy. Can you confirm this line item?
 - a. **The City's Standards and Specifications call out for all markings to be in thermoplastic (Section 8.5.4.4).**

2. Can you confirm if prevailing wages apply on 112th Ave Corridor Improvements?
 - a. **The project has federal funding and is subject to Davis Bacon minimum wages. Attention is directed to Page 2 of the Project Special Provisions. The Contractor shall go to CDOT's website to obtain the Standard Special Provision regarding minimum wages required for the project.**
<https://www.codot.gov/business/designsupport/cdot-construction-specifications/2017-construction-standard-specs/rev-ssp/rev-misc/cdot-db-min-wages-co180016/view>

3. I was going through the specs for the 112th Ave Corridor Improvements project and had a question. I don't see the liquidated damages, prevailing wage sheet, or special provisions included, can you please let me know where I can find these?
 - a. **Attention is directed to Page 2 of the Project Special Provisions. The Contractor shall go to CDOT's website to obtain the Standard Special Provision regarding liquidated damages for the project.**
<https://www.codot.gov/business/designsupport/cdot-construction-specifications/2017-construction-standard-specs/rev-ssp/rev-sec100-ssp/108ld/view>
 - b. **The project has federal funding and is subject to Davis Bacon minimum wages. Attention is directed to Page 2 of the Project Special Provisions. The Contractor shall go to CDOT's website to obtain the Standard Special**

Provision regarding minimum wages required for the project.

<https://www.codot.gov/business/designsupport/cdot-construction-specifications/2017-construction-standard-specs/rev-ssp/rev-misc/cdot-db-min-wages-co180016/view>

- c. The Project Special Provisions are located in the Invitation For Bid package right before the project plans.**
4. Bid Bond Form? Amount? 5%?
 - a. Attention is directed to Page 3 – Notice to Bidders of the Project Special Provisions. The proposal guaranty shall be a certified check, cashier’s check, or bid bond in the amount of 5 percent of the Contractor’s total bid.**
5. Testing costs by owner?
 - a. The City will provide Quality Assurance testing only.**
6. Surveying?
 - a. Construction Surveying is the responsibility of the Contractor and there is a bid item for this - Bid Item #82.**
7. On Plan page 28 under “Traffic Signal Notes” Note # 7 reads “All poles, mast arms, and luminaire arms shall be purchased and provided by the city”. The bid summary does not list the poles and mast arms as “Install Only”. Please confirm if the city will be providing the Poles, Mast Arms, and Luminaire arms for installation?
 - a. Any traffic signal equipment (poles, mast arms, luminaire arms, traffic signal faces, controller cabinets, etc.) WILL NOT be purchased by the City. These will need to be included in the Contractors bid and there are several 614 pay items for these items.**

City of Northglenn
Daniel Martinez
Civil Engineer II

Attachments: None

END OF ADDENDUM NO. 2