



## **CITY OF NORTHGLENN**

### **Addendum No. 1**

PROJECT TITLE: Terminal Reservoir Influent Pipeline Repair

PROJECT NO.: 2018-024

To: Prospective Bidders and Bid Holders

Date: November 20, 2018

This addendum shall become a part of the contract documents as if originally included. All other conditions and requirements of the Specifications will remain unchanged. All those submitting bids shall acknowledge receipt of addendum number 1 in the Proposal.

A bid bond is not required.

Please do not use straw as a mulching material. Staked down erosion control blankets and netting can be used, or a spray tacked mulch such as hydramulch.

The contractor will be required to install a gate in the fencing near the southwest corner of the reservoir to be used for access to the spoils area. The gate must be of similar quality to the existing fence. The gate can be removed after the project is completed, or can remain in place. It must be verified locked each day, and plant security is to be maintained at all times.

The piezometer and survey monument locations and depths are located in the tables on sheet 9 of the drawings. The piezometer locations and depths are approximate, and may change due to existing soil conditions found during construction. Therefore, a geotech must be present to log the hole while drilling.

If backfill material is found to be too saturated, materials from the spoils property southwest of the property may be used for backfill.

This Addendum must be signed, attested below, and attached to the Bid submitted to the Purchasing Agent or the Bid may be rejected.

By: \_\_\_\_\_  
Title

\_\_\_\_\_  
\_\_\_\_\_

ATTEST: \_\_\_\_\_

BIDDER:

\_\_\_\_\_

Date: \_\_\_\_\_

Company: \_\_\_\_\_

Address: \_\_\_\_\_

\_\_\_\_\_

Attachment  
Pre-Bid Sign in Sheet

**END OF ADDENDUM NO. 1**



MANDATORY PRE-BID CONFERENCE FOR

TERMINAL RESERVOIR INFLUENT PIPELINE REPAIR

NOVEMBER 8<sup>TH</sup> 2018, 10:00 AM

SIGN IN SHEET

	COMPANY	NAME	PHONE	EMAIL
1	CapS	John Turner	203 591-3442	jturner@CapS.com
2	ESCO Construction	David Stewart	720-483-2458	Dstewart@EscocoMailbox.com
3	SUNBEL RENTALS	CHRIS THOMPSON	970-301-6005	CHRISTOPHER.THOMPSON@SUNBELRENTALS.COM
4	<del>ESCO</del>			
5	C&K water Solutions	ERIC PASSARO	303-791-2521	eric.passaro@C&KSI.COM
6	T. LOWELL CASST	LEVI LOWELL	303.688.2530	LEVI@TLOWELLCONSTRUCTION.COM
7	BT Construction, Inc.	Drew Biling	31469-0199	Drew.Biling@BTConstruction.com
8	NeZhou	Judson Kipp	970-291-9543	Judson.Kipp@STUDIO7NORTH.COM
9	AMERICAN WEST CONSTRUCTION	PAUL SNYDER	3-455-2838	PSNYDER@AMWESTAEC.COM
10	STBS PIPELINE CONSTRUCTION	JT TURNER	3-299-4354	jt@stbspipeline.com
11	NCC	Will Vickers	303-857-1754	wlv@ncc-construction.com
12	J.R. Filanc	Trey Haltom	303-376-6337	thaltom@filanc.com
13	JR Filanc Construction	Laura Glorser-McCabe	303-376-6337	lwhittaker@filanc.com



MANDATORY PRE-BID CONFERENCE FOR

TERMINAL RESERVOIR INFLUENT PIPELINE REPAIR  
NOVEMBER 8<sup>TH</sup> 2018, 10:00 AM

SIGN IN SHEET

	COMPANY	NAME	PHONE	EMAIL
1	AG UNDERGROUND	Alyson Buum	970-616-5226	alyson@abunderground.com
2	HAMON	RUSTY SWERDEGER	3044-7345	RSWERDEGER@HAMON-INFRASTRUCTURE.COM
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				